



bioenergy2020+



Load cycle test for biomass boilers

Markus Schwarz, Elisa Carlon

Graz, 19/02/2017

Current standard: EN 303-5

- Standard test method to certify efficiencies and emission factors of biomass boilers
 - Stationary operation: 6 hours at full load (100%) and 6 hours at part (30%) load
- Currently used to rate performance and compare different products



LIMITS OF EN 303-5

- Today majority of boilers in the market show efficiency above 90% and low emission factors → EN 303-5 cannot be used any more to compare products
- Test in stationary operation does not reflect real conditions (dynamic regime)

Dynamic test methods

- Test methods to approach real life operating conditions:
 - *Bales et. al: 6-day test based on realistic climate sequence*
 - *Haberl et al: 12-day Concise Cycle Test for combined biomass-solar systems*

- Long duration → Relevant effort and resources
- Special equipment & Data post processing




Tests can be used for research purposes but cannot be widely adopted by industry

LOAD CYCLE TEST : new method to determine annual efficiency and emissions:


- Test is feasible in one working day with similar experimental set up as EN 303-5 tests → minimum expenses and effort in addition to EN 303-5
- All phases of boiler operation are included (ignition, different loads, stop, standby)
- Test results are representative of the boiler performance over the whole year

Case study and experimental setup in the laboratory

- The test emulates the operating conditions of boilers installed in **residential buildings** and **without a buffer storage tank**
- Boiler used to heat a “virtual house”, represented by a time variable demand profile






heat exchanger dissipates heat, according to a time variable profile, simulating a heat & DHW demand



Load profile



- Literature review and field measurement to find typical daily profiles of heating and DHW demand in different seasons (winter, summer, spring/autumn)
- Reduction to load levels defined in DIN 4702-8 (referred to the boiler's nominal capacity)
- Weighted sum of the daily load levels to define an annual reference cycle
- Cycle is completed with load transitions and reduced from 24 to 8 hours




Boiler control during the test

- Heat extracted by the heat exchanger, according to the load profile
 - Constant set values of flow and return T
 - Time variable water flow rate
- $$Q = mc_p(T_{\text{flow}} - T_{\text{ret}})$$


as hydronic heating systems in real life
-
- Last load step 13% → below lower limit of modulation range → boiler response to extremely low demands
 - Heat exchanger dissipates 13% of nominal load
 - No buffer storage
- Increase of water temperature in the circuit until boiler stops



Complete test cycle



Example of test results: 12 kW boiler



Heat dissipated by heat exchanger, representing the DEMAND side

Heat supplied by the boiler to fulfill the heat demand

Boiler's load modulation range: 30-100%

Load levels equal and lower than 30% cause overheating in the water circuit



When T inside boiler reaches 85 °C, the boiler stops for safety reasons → cycling operation in the final part of the load cycle

Reproducibility of test method

- Test repeated in different institutes in the EU (Austria, Germany, Spain, Greece)
 - 12 tests on 12 KW pellet boiler, 4 institutes
 - 5 tests on a 6 kw pellet boiler, 3 institutes
- Results shows reproducibility of test method

	12 kW Boiler	
	average	std deviation
efficiency [%]	78.7	2.1
CO [kg/TJ]	173.7	45.5
NOx [kg/TJ]	79.9	11.3
OGC [kg/TJ]	4.7	3.0
Dust [kg/TJ]	16.1	2.1

	6 kW Boiler	
	average	std deviation
efficiency [%]	73.9	1.7
CO [kg/TJ]	461.5	44.0
NOx [kg/TJ]	81.5	25.9
OGC [kg/TJ]	14.3	8.8
Dust [kg/TJ]	27.6	2.0





Comparison with real life operation

12 kW Boiler			
	Type Test EN 303-5 (full load)	Load cycle test	Real life operation
CO kg/TJ	21	173.7	231.0
NOx kg/TJ	79	79.9	92.2
OGC kg/TJ	1	4.7	3.9
Dust kg/TJ	7	16.1	13.8
Efficiency %	91.4*	78.7	77.5

* based on fuel consumption

■ Real life operation:

- Emissions: 24 h field measurements
- Median values of 17 measurements





Results – 3: development of new product

- New version of a pellet boiler of an Austrian company
- EN 303-5 test results do not show improvements

	EN 303-5 (full load)		EN 303-5 (part load)	
	Old	New	Old	New
CO kg/TJ	27	25	88	94
OGC kg/TJ	1	1	1	3
Dust kg/TJ	6	6	13	9
Efficiency %	93.2	94.4	90.9	89.6

- LCT results show significant emission reduction (OGC) and + 6% efficiency

	Load cycle test	
	Old	New
CO kg/TJ	287	301
OGC kg/TJ	16	4
Dust kg/TJ	20	17
Efficiency %	75.2	80.7



Conclusions

- Load Cycle Test method was developed, to estimate annual efficiency and emissions at the test stand
 - Repeatability of method was demonstrated
 - Method validated in comparison to field data

- The Load Cycle Test method:
 - is reliable tool to assess boiler performance under realistic operating conditions
 - can be used to evaluate the improvement of new products, in comparison to the current state of the art

Acknowledgments

- *ISEB Project*

Funded by bmvit und bmwfj within the program „ENERGIE DER ZUKUNFT“
 Managed by FFG



- *BioMaxEff Project (www.biomaxeff.eu)* **BioMaxEff**

The research leading to these results has received funding from the European Union Seventh Framework Programme (FP7/2007-2013) under Grant Agreement n° 268217



**THANK YOU FOR YOUR
 KIND ATTENTION!**