



COAL-BIOMASS COFIRING

PRACTICAL CONSIDERATIONS

Larry Felix
Southern Research Institute

DOE Cooperative Agreement No. DE-FC26-00NT40895



Southern Research Institute

Why Biomass Cofiring?

- Cofiring Helps to Reduce SO_2 and NO_x Emissions Legislatively Targeted for Reduction
- Renewable Energy may be Mandated at a percentage of a Utilities Energy Output
- U.S. Tax Advantages for the Production of Energy from Renewable Fuels
- Climate Protection – Global Warming



US Consensus

“The addition of biomass has been shown to reduce NO_x emissions in most commercial facilities, usually beyond the reductions expected because of a lower overall fuel-bound nitrogen content. The high volatiles content of biomass can effectively establish a fuel-rich zone early in the flame that can reduce NO_x emissions. Adding biomass can reduce flame temperatures, leading to lower levels of thermal NO_x. The high moisture content of some biomass may also be effective for NO_x reduction at full-scale.”¹

¹ Dayton, David, *A Summary of NO_x Emissions Reduction from Biomass Cofiring*, DOE Contract DE-AC36-99-GO10337, NREL/TP-510-32260, National Renewable Energy Laboratory, Golden CO, May, 2002, p.3




Full-Scale Experience in the US

| Plant | Biomass | % | NO _x Result | Reference |
|------------------------------|-------------------|------|-----------------------------|--------------------------------------|
| Hammond | Wood | 13 | No effect | Boylan, et al., 1992 |
| Kraft | Wood | 0-30 | Reduced > fuel N | Boylan, et al., 1994 |
| Greenidge Station | Dry wood | 10 | No effect | Prinzing et al, 1996 |
| Greenidge Station | Wet wood | 10 | Reduced | Prinzing et al, 1996 |
| Madison Gas & Electric | Switchgrass | 14 | No to slight effect | Ragland et al, 1996 |
| Allen Fossil Plant | Wood | 0-20 | Reduced > fuel N | Tillman et al, 1996 |
| Sandia Pilot | Wood, switchgrass | 0-66 | Reduced ∞ to fuel N | Baxter and Robinson, 1999 |
| Seward, Allen, Michigan City | Wood | 0-20 | Reduced < fuel N on average | Tillman, Plasynski, and Hughes, 1999 |
| Gadsden | Switchgrass | 10 | No effect | Boylan, 2001 |
| Colbert | Wood | 1-5 | Up to 16% Increase | Dayton, 2002 |



US Results – Mass Basis (Dayton – NREL, May 2002)

Summary of NO_x Reduction from Biomass/Coal Cofiring



A summary of NO_x reduction from a number of biomass/coal cofiring full-scale and pilot-scale demonstration tests, based on the mass input of biomass. Dashed lines are 95% prediction limits that encompass the range of variability in the measured data.



At the Pilot Scale




Combustion Research Facility


- All testing conducted at the SRI/SCS 6.0 MMBtu/hr Combustion Research Facility (at 3.5 MMBtu/hr)
- Continuous measurement and logging of ~ 200 pertinent process parameters
- In-situ testing for mass emissions, particle size, char, pyrometry, ash resistivity, gases (O_2 at furnace exit and at CEM location, CO , CO_2 , SO_2 , NO_x , NH_3 , H_2O , HCl).
- On-site wet chemical flue gas and ash analyses, CHN (for carbon in ash), fuel heat value measurement
- Instrumented CE-Raymond Model 352 Deep Bowl mill




Combustion Research Facility (CRF) Temperature/Time Histories Compared with Those of Full-Scale SCS Plants




Pilot-Scale Test Facility



Locations for Biomass Injection





Milling Coal and Biomass



SRI / SCS

CE-Raymond
Model 352
Deep Bowl Mill



Southern Research Institute

Analyses of Fuels

| ANALYSIS | COAL | BIOMASS | |
|--------------------------------|-------------------------------|------------------------------|--------------------|
| | Eastern hv bit. Pratt Seam | Switchgrass Field Chopped | Sawdust Red Oak |
| PROXIMATE (As Received) | | | |
| MOISTURE, % | 2.64 | 15.18 | 3.11 |
| ASH, % | 16.08 | 29.53 | 0.52 |
| VOLATILE, % | 33.14 | 47.69 | 82.45 |
| FIXED CARBON, % | 48.14 | 7.60 | 13.92 |
| SULFUR, % | 1.47 | 0.21 | 0.01 |
| HEAT VALUE, Btu/lb | 12760 | 5891 | 8017 |
| ULTIMATE (Dry) | | | |
| CARBON, % | 69.53 | 36.59 | 48.97 |
| HYDROGEN, % | 4.64 | 3.50 | 6.09 |
| NITROGEN, % | 1.60 | 1.59 | 0.15 |
| SULFUR, % | 1.51 | 0.25 | 0.01 |
| ASH, % | 16.52 | 34.82 | 0.54 |
| OXYGEN, % (DIFF) | 6.20 | 23.25 | 44.24 |
| CHLORINE, % | 0.01 | 0.10 | 0.01 |



MILLING COAL AND BIOMASS-1

| MILLING RATES | UNIT | COAL | SAWDUST | | SWITCHGRASS | |
|------------------------|--------|------------|---------|-------|-------------|-------|
| | | Pratt Seam | 10% | 20% | 15% | 20% |
| Net Coal Added to Bins | lb/h | 1052.0 | 626.5 | 652.8 | 358.8 | 265.5 |
| Coal Burned | lb/h | 0.0 | 278.6 | 126.2 | 311.3 | 309.5 |
| Fuel Heat Value | Btu/lb | 12760 | 12323 | 12085 | 12089 | 11911 |
| Mill Output | lb/hr | 1052.0 | 905.1 | 779.0 | 670.0 | 574.9 |
| Mill Rejects | lb/h | 30.0 | 25.2 | 24.4 | 19.0 | 15.1 |



MILLING COAL AND BIOMASS - 2

| AVERAGES | UNIT | COAL | SAWDUST | | SWITCHGRASS | |
|------------------------------|---------|------------|---------|-------|-------------|-------|
| | | Pratt Seam | 10% | 20% | 15% | 20% |
| Mill Current | Amps | 43.2 | 45.5 | 51.2 | 44.1 | 43.0 |
| Drying Natural Gas | scfh | 112.0 | 100.2 | 63.5 | 66.0 | 82.1 |
| Mill Inlet Temperature | °F | 185.2 | 179.9 | 172.6 | 161.8 | 176.3 |
| Mill Outlet Temperature | °F | 145.0 | 145.1 | 145.0 | 135.1 | 145.0 |
| Mill Exit Gas Flow | ACFM | 2259 | 2260 | 2261 | 2260 | 2259 |
| Mill Exit Gas Flow | SCFM | 1965 | 1961 | 1959 | 1989 | 1952 |
| ΔP at Mill Inlet | in. H2O | -0.25 | -0.25 | -0.24 | -0.25 | -0.25 |
| O ₂ at Mill Inlet | % | 16.9 | 17.2 | 18.2 | 11.7 | 12.7 |
| Mill Spring Pressure, West | lbs | 1259 | 2358 | 3614 | 2163 | 2057 |
| Mill Spring Pressure, East | lbs | 3786 | 5665 | 8006 | 5048 | 4842 |
| Journal Lift, West | in. | 0.16 | 0.18 | 0.18 | 0.17 | 0.20 |
| Journal Lift, East | in. | 0.16 | 0.18 | 0.18 | 0.17 | 0.18 |
| Hardgrove Grindability | no unit | 49.0 | N/A | N/A | N/A | N/A |




MILLING COAL AND BIOMASS - 3

| CALCULATED ENERGY USAGE | UNIT | COAL | SAWDUST | | SWITCHGRASS | |
|---------------------------------|----------|------------|---------|-------|-------------|-------|
| | | Pratt Seam | 10% | 20% | 15% | 20% |
| Fuel Heat Value | Btu/lb | 12760 | 12323 | 12085 | 12089 | 11911 |
| Mill Output | MBtu/hr | 13.4 | 11.2 | 9.4 | 8.1 | 6.8 |
| Specific Grinding Energy, gross | kW/ton | 24.7 | 30.2 | 39.8 | 39.7 | 45.0 |
| Specific Grinding Energy, net | kW/ton | 3.79 | 5.78 | 10.81 | 6.73 | 6.76 |
| Specific Drying Energy | Btu/lb | 113.0 | 117.4 | 86.2 | 105.4 | 151.9 |
| Specific Grinding Energy, gross | kWh/MBtu | 0.97 | 1.23 | 1.65 | 1.64 | 1.89 |
| Specific Grinding Energy, net | kWh/MBtu | 0.15 | 0.23 | 0.45 | 0.28 | 0.28 |
| Specific Drying Energy | Btu/MBtu | 8857 | 9530 | 7133 | 8715 | 12752 |
| Hardgrove Grindability | no unit | 49.0 | N/A | N/A | N/A | N/A |




Biomass Comilled with HV Bituminous Coal



Size Distributions




80% Pratt Seam Coal - 20% Sawdust




**Is it the Biomass
OR
Does Coal Particle Size
Affect NO_x and/or UBC
Emissions?**




Regular Grind (70% < 200 mesh) and Fine Grind Coal



Pratt Seam Coal - Baseline Injection Configuration Effect of Normal and Fine Coal Grind NO_x Performance in the Pilot-Scale Combustor Dependence on Furnace Exit Oxygen



Pratt Seam Coal - Comilling Configuration Effect of Normal and Fine Coal Grind Unburned Carbon Performance in the Pilot-Scale Combustor



**With Comilling,
NO_x and UBC Emissions
are Apparently Unaffected
by More Finely Ground Coal
~90% <200 mesh**

